



201383  
ДСТУ ISO/IEC 17025

Атестат акредитації  
№ 201383  
Дійсний до  
16 червня 2021 року


79035, Україна, м. Львів  
вул. М.Пимоненка, 3  
тел.: (032) 294-82-87,  
e-mail: lablizo@ukr.net

Accreditation certificate  
№ 201383  
Expiry date:  
16 June, 2021

79035, Ukraine, Lviv  
st. Pymonenka, 3  
Tel.: (032) 294-82-87,  
e-mail: lablizo@ukr.net



APPROVED BY  
Head of the laboratory  
of the «LIZO Ltd.»

  
« 15 » 06 D. R. Dovhun  
2021.

## Protocol № 15/21

### *Static mechanical tests of the wire connector.*

**Requirements and test methods: clause 6.4 of IEC 62561-1:2019**

**Product name:** Universal wire connector

**Model and type:** C-011 ST

**Producer:** LLC "FS Lightning Protection"  
80383, Lviv region, Zhovkivsky r-n,  
Malekhiv 9/37, Vokzalna str.

**Ordering company:** LLC "FS Lightning Protection"  
80383, Lviv region, Zhovkivsky r-n,  
Malekhiv 9/37, Vokzalna str.

**Reason:** Agreement № 14-04-21 of 20.04.21.

**Test result:** Universal wire connector C-011 ST withstood  
mechanical tests and meets the requirements of  
clause 6.4 of IEC 62561-1:2019

the test results apply to the tested samples.

This protocol may not be reproduced, replicated and distributed as an official document in full or in part without the permission of the testing laboratory.

Lviv - 2021

Date of samples receipt: 03.05.2021  
 Number of samples: 3.  
 ID numbers of the samples: №1 ... №3.  
 Period of testing: 05-06.05.2021.  
 Environmental conditions:  
     temperature: 21,8 °C;  
     Atmospheric pressure: 97,9 kPa;  
     Relative humidity: 69 %.

### **1. Tested samples:**

Universal wire connectors:

Model and type: C-011 ST

### **2. Testing methods:**

The tests are performed on the collection of the samples, placed under normal operating conditions in accordance with the manufacturer's installation instructions, with the recommended conductive materials, sizes and tightening torques. Tests are performed on new samples.

Layout of samples.

Conductors and samples are cleaned with a degreasing agent followed by purification with non-mineralized (distilled) water and drying. Then they are assembled in accordance with the manufacturer's instructions with the recommended conductors and tightening torques.

The presented samples of the connector with wires were prepared in accordance with the customer's instructions. Tightening torque of the nut 18 Nm.

The connecting element is tested in the connection configurations stated by the manufacturer in accordance with Annex B of IEC 62561-1: 2019. Static mechanical tests were performed according to configuration B2, as shown in Annex B.

The tests were performed on three samples of a connector with a conductor with a diameter of 8 mm. Each conductor of the assembled samples was individually subjected to mechanical tension force of  $900 \text{ N} \pm 20 \text{ N}$  for 1 min. on the bursting machine (Pic.1)

### **3. Requirement:**

A connection element is considered to have passed the test if less than 1 mm of conductor movement is observed during the test and there is no damage to the connector or conductor

### **4. Testing results:**

Table 1 – Testing results

| Registration № of connector | Mechanical tension force, N | Exposure time, min. | Conductor movement, in mm | Connector/conductor damage | Accordance with clause 6.4 of IEC 62561-1 |
|-----------------------------|-----------------------------|---------------------|---------------------------|----------------------------|---|
| 1                           | 900                         | 1                   | No movement               | No damage                  | Corresponds                               |
| 2                           |                             |                     | No movement               | No damage                  | Corresponds                               |
| 3                           |                             |                     | No movement               | No damage                  | Corresponds                               |



**5. Conclusion:**

Presented for testing samples of universal wire connectors C-011ST withstood test and meet the requirements of clause 6.4 of IEC 62561-1: 2019 on the tested parameters

**6. Picture:**

Pic.1 – Connector during testing

**6. Means of measurement and tests:**

| № | Name                  | Model                 | Calibration date |
|---|-----------------------|-----------------------|------------------|
| 1 | Torque wrench         | DT-030S2 №17000067    | 07.04.2021.      |
| 2 | Test bursting machine | LIZO №001             | No calibration   |
| 3 | Dynamometer           | FB 50K №0032          | 07.04.2021.      |
| 4 | Stopwatch             | SOP pr-2a-3-000 №5353 | 08.04.2021.      |
| 5 | Ruler 1m              | VaGo-Tools №003       | 08.04.2021       |

**The tests were performed by:**

Deputy Head of the laboratory :

engineer:

S. S. Lakhovskyi

D. S. Denys